

STATEMENT ACCOMPANYING FORM - 'A'

1. Door number of the Building : 136A, 136B, Railway mixed High School main building.
2. Location (Street Number, ward Number, Name of place i.e. Corporation/Municipality/ Panchayat/ Panchayat Union/ Township/Concoment: **Romalia Railway Colony Tiruvative Palli**
3. Year of Construction : 1930-1931 ; 1978 (New)
4. Approximate cost of construction : Rs. 65000/-
5. Current cost : Rs. 18000 / Sqm
6. Purpose for which the building hitherto been used : Railway Mixed High School English Medium
7. Details of construction of the building
 Particulars of the foundation and soil, specification : Old Building - New Buildings
 Of the various parts in
 1. Foundation : Lime concrete - Cement concrete.
 2. Basement : RR masonry - RR masonry
 3. Super structure : Brick masonry - Brick masonry
 4. Floor & roof are to be given : Cement concrete / - Cement concrete
 RR Roof
 8. Period for which license is required : For 3yrs - 01.01.2018 to 31.01.2021
 Number of persons to be accommodated : 900

10.02.2018
 N.V.V. Srinivasan
 Sr. Section Engineer/ Works/A/GOC
 A.S. & P. for Inspection
 SSE/W/A/GOC
 Divisional Engineer/ Works/A/GOC
 Southern Railway
 Chennai
 P. O. Southern Railway
 Chennai
 महाराष्ट्र शासनाचे/मद्रास लोकसभेचे/मद्रास लोकसभेचे
 ADEN/Central/TPJ

FORM-A

Form of opinion under Sub-section 5 of the madras public building (Licensing Act) 1965 Madras Act 13 of 1965 referred to is rule 5 of the Madras Public Building (Licensing Rules) 1965.
 I have inspected the building specified in the statement below and I have satisfied myself that the building is structurally sound to be used as a Public building for the purpose specified in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian standards 875.

I am therefore of the opinion that a license may be granted for the period from 01.02.2018 To 31.01.2021 (Inclusive)

10/2/2018
 Divisional Engineer
 Southern Railway/TPJ (Gen)
 Chennai
 P. O. Southern Railway

N.V.V. Srinivasan
 Sr. Section Engineer/ Works/A/GOC
 A.S. & P. for Inspection
 SSE/W/A/GOC

Location of Building (Door No. Street No. Name, Place)	Age of the Building	Purpose for which the Building will be Structurally Sound	Number of person to be accommodated	Remarks
136A 136B Railway Mixed High School main Building	83yrs 31yrs	for School	900	

10/2/2018
 N.V.V. Srinivasan
 Sr. Section Engineer/ Works/A/GOC
 Divisional Engineer
 Southern Railway/TPJ
 Chennai
 P. O. Southern Railway
 Chennai
 महाराष्ट्र शासनाचे/मद्रास लोकसभेचे/मद्रास लोकसभेचे
 ADEN/Central/TPJ